



NOTES:

- 1) Minicloset-5 handles up to four (4) PDM Modules (total of 48 discrete inputs).
- 2) Water, gas, BTU, et. al. meters must be dry contact output type. (Form A - See specifications for details. Contact Manufacturer for more information.)
- 3) All electric and pulse data shall be collected via Power Line Carrier to the Scan Transponder.

| REVISIONS | | | |
|-----------|---------------------------------|----------|----------|
| REV. | DESCRIPTION | DATE | APPROVED |
| 2 | Changed label of the PDM units. | 05/16/06 | 06/01/06 |
| | | | |
| | | | |

| | | | |
|------------|-------|---|--------------|
| | | Quadlogic Controls Corporation TITLE MC-5 with PDM Installation Diagram | |
| SIGNATURES | | DATE | |
| MODEL | JREA | 10/18/05 | |
| DETAIL | | SIZE | DRAWING |
| APPROVED | JKIM | 17-MC5 PDM MOD REV2 | |
| APPROVED | MNE W | 06/01/06 | REV 2 |
| SCALE: | | | SHEET 1 of 1 |